


JIANGSU WUJIN KAILI ELECTRONIC FACTORY

SPECIFICATION SHEET

Natural Gas Detector Alarm

Model: OR-G909(II)

PRODUCT PICTURE	Main Feature:
	MCU processing High stability sensor Wall Mounted Independent & Network optional Power Input Method Optional Automatic fault detection Auto reset after alarm•
Technical Specification	
Induced Gas: Natural Gas / LPG Power Input: AC 220V 50Hz Or DC 12V Static Current: ≤150mA Alarm Current: ≤ 200mA Buzzer Level: ≥80dB/m Alarm Density: 10% LEL(0.5%)(5000PPM) Operating Temperature: -10℃ to + 50℃ Operating Humidity: ≤90% RH Alarm Density Error: ±3% LEL Alarm Mode: Flash & sound alarm / Network Alarm Signal Standard: GB15322-2003 EN50194 UL1484 Size: 110 * 95* 48mm	

JIANGSU WUJIN KAILI ELECTRONIC FACTORY

Miaoqiao Town, Changzhou city, Jiangsu, China 213167

TEL:0086-519-86462433; 86712320

FAX:0086-519-86471336; 86712320

E-mail: kailiec@jssmail.com.cn

<http://www.kaili-buzzer.com/>